
Pay Your Water Bill Online! Customers now have the ability to make payments online by accessing the City's website at <https://arcata.merchantransact.com/default.aspx>. The online payment system provides convenient paperless statements via email, ability to view and pay bills online, obtain account usage information, 24/7 account access, reduced time paying bills, and saving on stamps. For questions regarding the online process, please contact the Finance Department at (707) 822-5951.



Jacoby Creek Water District 2018 Consumer Confidence Report

April 2019

The City of Arcata (City) is responsible for providing safe, reliable, high quality drinking water to the Jacoby Creek Water District (District). The Consumer Confidence Report, or CCR, is an annual water quality report that the City is required to provide to customers in accordance with requirements of the Safe Drinking Water Act. The purpose of the CCR is to raise customers' awareness of the quality of their drinking water, where their drinking water comes from and the importance of protecting drinking water sources. Please take a moment to read through this report to learn about the quality of your drinking water. This report shows the results of drinking water monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Ciudad de Arcata a 707-822-5953 para asistirlo en español.

In 2018, results from our water quality monitoring and testing program indicate that our water quality is very good, as has consistently been the case in past years. Last year more than 1,000 tests for more than 100 constituents were conducted on your drinking water. None of these constituents were detected at a level higher than allowed by drinking water regulations. Sampling results for constituents that were detected in your drinking water are presented in the [Sampling Results](#) section of this report.

Where Does My Drinking Water Come From?

The source of drinking water for the District is groundwater purchased from [Humboldt Bay Municipal Water District](#) (HBMWD). This classification is important due to the regulations that the HBMWD, the City and the District must follow to ensure water quality.

Drinking water purchased from HBMWD is drawn from wells located in the bed of the Mad River northeast of Arcata. These wells, called Ranney Wells, draw water from the sands and gravel of the aquifer at depths of 60 to 90 feet, thereby providing a natural filtration process. During the summer, this naturally filtered water is disinfected with chlorine before being delivered to the City via transmission lines to the Alliance Road Transfer Station, Wymore Intertie and Aldergrove Intertie. During the winter, prior to disinfection, the groundwater is treated at HBMWD's Turbidity Reduction Facility to reduce occasional turbidity (cloudiness) in the source water. While turbidity itself is not a health concern, at elevated levels, turbidity could potentially interfere with the disinfection process.

Prior to distribution to the District, the City adds fluoride to an optimal level to prevent tooth decay. You may obtain more information about fluoridation, oral health, and current issues at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.shtml.

Source Assessment & Vulnerability Assessment

A Drinking Water Source Assessment conducted by the California Drinking Water Source Assessment and Protection Program, completed in August 2002, classified HBMWD's Ranney Wells as a groundwater source which is most vulnerable to the following activities not associated with any detected contaminants: lumber processing and manufacturing, low density septic systems, wood preserving/treating and wood/pulp/paper processing and mills. Due to the detection of aluminum, Ranney Wells are considered vulnerable to activities that may have contributed to, or caused the release of aluminum. In particular, aluminum is believed to be associated with the residue from some surface water treatment processes and erosion of natural deposits. Due to the detection of barium, Ranney Wells are considered vulnerable to activities that may have contributed to, or caused the release of barium. In particular, barium is believed to be associated with discharges of oil drilling wastes and metal refineries and erosion of natural deposits.

The Drinking Water Source Assessment report is available through the State Water Resources Control Board (SWRCB) by contacting SWRCB, Division of Drinking Water, District 01 at (530) 224-4800 or 364 Knollcrest Drive, Suite 101, Redding, CA 96002.

Additional Information about Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health. For more information on bottled and vended water regulations and quality standards visit the California Department of Public Health at <https://www.cdph.ca.gov/Programs/CEH/DFDCS/Pages/FDBPrograms/FoodSafetyProgram/Water.aspx>

Drinking Water and Your Health

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Sampling Results

The tables on the following pages list all of the drinking water contaminants that were detected during the most recent sampling for the contaminant. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Drinking water regulations allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Consequently, some of the data, though representative of the water quality, were collected prior to 2018.

Representative samples are collected at various points in the drinking water treatment and distribution systems. Sample/Source Locations identified in the sample results table are further described below:

- “HBMWD” - data provided by HBMWD and representative of untreated source water or fully-treated water purchased from HBMWD.
- “Distribution System”- collected from locations throughout the distribution system and representative of treated water delivered to customers.

TERMS USED IN THIS REPORT	
<p>Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p>	<p>ND: Not detectable at testing limit</p>
<p>Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p>	<p>NTU: Nephelometric Turbidity Units</p>
<p>Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p>	<p>ppb: Parts per billion or micrograms per liter ($\mu\text{g/L}$). One ppb is equivalent to one second in nearly 32 years.</p>
<p>Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p>	<p>ppm: Parts per million or milligrams per liter (mg/L). One ppm is equivalent to one second in 11.5 days.</p>
<p>N/A: Not applicable</p>	<p>Primary Drinking Water Standards (PDWS): MCLs, MRDLs and Treatment techniques (TTs) for contaminants that affect health along with their monitoring and reporting requirements.</p>
	<p>Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p>
	<p>Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p>
	<p>Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.</p>
	<p>$\mu\text{S/cm}$: microSeimens per centimeter</p>

Coliform bacteria monitoring in the distribution system is conducted throughout the month. Total coliform and *E. coli* monitoring results are presented in Table 1.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA IN 2018					
Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	0 (In a month)	0	1 positive monthly sample	0	Naturally present in the environment.
<i>E. coli</i> (state Total Coliform Rule)	0 (In the year)	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste.
<i>E. coli</i> (federal Revised Total Coliform Rule)	0 (In the year)	0	See Footnote (a)	0	Human and animal fecal waste.

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Sodium and hardness do not have Maximum Contaminant Levels (MCLs) or Public Health Goals (PHGs) however, they are of interest to many consumers. Sodium refers to the salt present in water. Hardness is the sum of polyvalent cations present in water, generally magnesium and calcium. Sodium and hardness data are presented in Table 2.

TABLE 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS					
Constituent (reporting units)	Sample Source/Location	Year Sampled	Average	Range	Typical Source of Contaminant
Sodium (ppm)	Distribution System	2016	3.9	N/A	Generally naturally occurring.
Hardness (ppm as CaCO ₃)	Distribution System	2016	100	N/A	Usually naturally occurring.

Lead and copper monitoring is conducted throughout the water distribution system to determine whether there is any evidence of lead or copper in the tap water of our community. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for

several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize your exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead> and at <https://www.epa.gov/dwreginfo/lead-and-copper-rule>. Lead and copper monitoring results are presented in Table 3.

In 2017 and 2018, the State Water Resources Control Board Division of Drinking Water (DDW) issued new guidelines for lead testing in K-12 schools. Public schools that are served by a public water system are required to have their drinking water sampled for lead. Private schools that are served by a public water system may request to have their drinking water sampled for lead. The District is responsible for conducting drinking water sampling and providing technical assistance if an elevated lead sample is found. Mandatory and voluntary school drinking water lead testing must be conducted before July 1, 2019. No schools served by the District were sampled for lead in 2018.

For questions about any aspect of lead testing of drinking water in California schools, send an email to DDW-PLU@waterboards.ca.gov, call (916) 449-5646 or visit: https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/leadsamplinginschools.html.

USEPA El plomo del agua potable en las escuelas y los centros de cuidado infantil:

<https://espanol.epa.gov/espanol/el-plomo-del-agua-potable-en-las-escuelas-y-los-centros-de-cuidado-infantil>

TABLE 3 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER (testing conducted in 2016)							
Constituent (reporting units)	No. of Samples Collected	90th Percentile Level Detected	No. of Sites Exceeding the AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	6	1.6	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	6	0.7	0	1.3	0.3	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Primary Drinking Water Standards (PDWS) are established for contaminants that affect health. Monitoring results for contaminants with PDWS are presented in Table 4.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD							
Constituent (reporting units)	Sample Source/Location	Year Sampled	Average	Range	MCL	PHG	Typical Source of Contaminant
Inorganic Constituents							
Aluminum (ppm)	HBMWD	2015	0.011	N/A	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes.
Fluoride (ppm)	Distribution System	2018	0.46	ND – 1.16	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Disinfection Byproducts and Disinfectant Residuals							
Chlorine (ppm)	Distribution System	2018	0.4	0.2 – 0.7	MRDL = 4.0 (as Cl ₂)	MRDLG = 4.0 (as Cl ₂)	Drinking water disinfectant added for treatment.
TTHMs -Total Trihalomethanes (ppb)	Distribution System	2018	16	N/A	80	N/A	Byproduct of drinking water disinfection.
HAA5 -Haloacetic Acids (ppb)	Distribution System	2018	3.8	N/A	60	N/A	Byproduct of drinking water disinfection.

Secondary Drinking Water Standards (SDWS) are established for contaminants that affect aesthetics such as taste, odor or the appearance of drinking water. There are no PHGs or Maximum Contaminant Level Goals (MCLGs) for constituents with SDWS because secondary MCLs are set on the basis of aesthetics. Contaminants with SDWS do not affect health at MCL levels. Monitoring results for contaminants with SDWS are presented in Table 5.

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Constituent (reporting units)	Sample Source/Location	Year Sampled	Average	Range	Secondary MCL	Typical Source of Contaminant
Chloride (ppm)	Distribution System	2016	4.0	N/A	500	Runoff/leaching from natural deposits; seawater influence.
Color (color units)	HBMWD	2016	5.0	N/A	15	Naturally-occurring organic materials.
Specific Conductance ($\mu\text{S}/\text{cm}$)	HBMWD	2018	130	N/A	1600	Substances that form ions when in water; seawater influence.
Sulfate (ppm)	Distribution System	2016	11	N/A	500	Runoff/leaching from natural deposits; industrial wastes.
Total Dissolved Solids (ppm)	Distribution System	2016	120	N/A	1000	Runoff/leaching from natural deposits.
Turbidity (NTU)	Distribution System	2018	0.12	0.04 – 1.00	5	Soil runoff. See Footnote (b).

(b) Turbidity is a measure of the cloudiness of the water and is a good indicator of water quality. Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms.

Additional Sampling

In addition to monitoring required by the Safe Drinking Water Act, the District monitors for unregulated constituents that some consumers may find of interest. The results of this monitoring are presented in Table 6.

TABLE 6 - SAMPLE RESULTS OF NON-REGULATED TESTING					
Constituent (reporting units)	Sample Source/Location	Year Sampled	Average	Range	Additional Information
Alkalinity (ppm as CaCO_3)	Distribution System	2016	83	N/A	Alkalinity is a measure of the buffering capacity of water or its ability to resist change in pH.
Corrosivity (Langlier Units)	Distribution System	2016	-0.28	N/A	Corrosivity values in this range indicate that the water is slightly corrosive on the Langlier Index.

As part of the federal drinking water program, USEPA issues a list of currently unregulated contaminants to be tested by public water systems throughout the nation. This process occurs every five years pursuant to the Unregulated Contaminant Monitoring Rule (UCMR). The purpose of the UCMR program is to determine the prevalence of unregulated contaminants in drinking water. Results of this testing help USEPA determine whether or not to regulate new contaminants for protection of public health.

There have been four cycles of monitoring: UCMR 1 (2001-2003), UCMR 2 (2008-2010), UCMR 3 (2013-2015) and UCMR 4 (2018-2020). Small community water systems are not required to participate in UCMR testing, unless randomly selected by USEPA. The District has never been selected for UCMR monitoring participation. However, the City and Humboldt Bay Municipal Water District have participated in UCMR testing. Results of UCMR 3 constituents detected at the entry point to the City's distribution system are presented in Table 7. Table 8 shows UCMR 4 sampling results from HBMWD source water. The City is scheduled to begin UCMR 4 monitoring in 2020.

TABLE 7 - SAMPLE RESULTS OF UCMR 3 - DETECTED CHEMICALS (testing conducted in 2015 by the City)						
Constituent (reporting units)	Average	Range	Levels & Goals			Likely Source
			Notification Level	MCL	PHG	
Chromium VI/ Hexavalent Chromium (ppb)	0.19	0.16 – 0.21	N/A	10	0.02	Naturally occurring from geological formations, also from manufacturing of textile dyes, wood preservation, leather tanning, and anti-corrosion coatings.
Chromium, Total (ppb)	0.24	0.21 – 0.27	N/A	50	N/A	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.
Strontium, Total (ppb)	270	260 – 280	N/A	N/A	N/A	Strontium is a silvery metal that rapidly turns yellowish in air. Strontium is found naturally as a non-radioactive element. Strontium has 16 known isotopes. Naturally occurring strontium is found as four stable isotopes Sr-84, -86, -87, and -88. Twelve other isotopes are radioactive.
Vanadium, Total (ppb)	0.48	0.47 – 0.49	50	N/A	N/A	Naturally-occurring; the primary possible contaminating activity is steel manufacturing and in association with hazardous waste sites.
Chlorate (ppb)	23	ND – 25	800	N/A	N/A	Agricultural defoliant or desiccant; used in production of chlorine dioxide.

TABLE 8 - SAMPLE RESULTS OF UCMR 4 - DETECTED CHEMICALS (testing conducted in 2018 by HBMWD)				
Constituent (reporting units)	Average	Range	Notification Level	Health Effect Language
Manganese (ppb)	2.0	N/A	500	Manganese exposures result in neurobiological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.
Bromide (ppb)	14	11-18	N/A	Indicator of the potential to form haloacetic acids during water treatment. Bromide itself has low human toxicity.
Total Organic Carbon (ppb)	0.55	0.53 - 0.57	N/A	Indicator of the potential to form haloacetic acids during water treatment. Total Organic Carbon has no know health effect.

Additional Information

The City strives to provide excellent quality water and service to our customers. If you have any questions about your drinking water or this report call Rachel Hernandez, Environmental Compliance Officer at (707) 822-2148. You may also attend a regularly scheduled Arcata City Council meeting held the first and third Wednesday of each month at 6 p.m. in the Council Chamber, 736 F Street, Arcata, CA, to hear, discuss, or deliberate upon any item or subject within the City's jurisdiction.

Landlords. Tenants may not receive this report since they may not be direct customers of the City. You should make this report available to such people by posting it in a conspicuous place, distributing copies to all tenants or by directing tenants to <http://www.cityofarcata.org/327/Water-Quality-Reports>.

Cross Connection Protection. Backflow prevention assemblies are designed to allow water to flow into your home or business from the public water system while not allowing water to flow in the reverse direction. Reverse flow can carry untreatable pollutants and contaminants into the public water system, which compromises water quality for all customers. Backflow prevention assemblies are required to be tested annually to ensure they are effectively protecting the public water system. If your residence has a well on the premises or your business has fire sprinklers and/or landscaping, then you likely have a backflow prevention assembly. For questions regarding annual testing requirements call Mike Clinton, Deputy Director of Environmental Services, Streets and Utilities at (707) 822-8184.